


IMO Resolution MSC 307(88) (2010 FTP Code): Annex 1: Part 2



Smoke & Toxicity

A Report To: WSBL Ltd.

Document Reference: 502169

Date: 8th July 2021

Issue No.: 1

Expiry Date: 18th May 2036

Page 1



0249

Executive Summary

Objective To determine the performance of the following product when tested in accordance with IMO Resolution MSC 307(88): Annex 1: Part 2.


Generic Description		Product reference	Thickness	Weight per unit area or density
Polymeric decoupled acoustic barrier mat		"Revac® Momentum™ S FF"	5.0mm	2.0g/cm ³
Individual components used to manufacture composite:				
Facing	Foil	Unable to provide	Unable to provide	Unable to provide
	Reinforcing scrim	Unable to provide	Unable to provide	Unable to provide
	Adhesive	Unable to provide	Unable to provide	25g/m ²
Rubber	"Revac® Momentum™ S"	5.0mm	2.0g/cm ³	
Please see pages 5 & 6 of this test report for the full description of the product tested				


Test Sponsor WSBL Ltd., Durbar Mill, Hereford Road, Blackburn, Lancashire, BB1 3JU

Summary of Test Results: **The specimens meet all the criteria for smoke generation and toxicity for bulkhead, wall and ceiling products as specified in the Resolution.**

Date of Test 21st & 22nd April and 19th May 2021

Signatories


Responsible Officer
K. Deluce *
Testing Officer


Authorised
J. Lucas-Cox *
Operations Manager

* For and on behalf of [Warringtonfire](#).

Report Issued: 8th July 2021

This version of the report has been produced from a .pdf format electronic file that has been provided by [Warringtonfire](#) to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of [Warringtonfire](#).

CONTENTS	PAGE NO.
EXECUTIVE SUMMARY	2
TEST DETAILS	4
DESCRIPTION OF TEST SPECIMENS	5
TEST RESULTS	7
APPENDIX I – SMOKE PRODUCTION DURING TEST	9
APPENDIX II – TOXICITY PRODUCTION DURING TEST	10
APPENDIX III – OBSERVATIONS DURING TEST	12
REVISION HISTORY	13



Test Details

Purpose of test	<p>This test method, adopted by the International Maritime Organisation, specifies a procedure for qualifying smoke generation and toxic potency of products and thus their suitability for use in maritime construction.</p> <p>The test was performed in accordance with the procedure specified in IMO Resolution MSC 307(88): Annex 1, Part 2 and it is advised that this report is read in conjunction with this document.</p>
Scope of test	<p>International Maritime Organisation Resolution MSC 307(88): Annex 1, Part 2 incorporates the following methods:</p> <p>Appendix 1 – Test procedure for smoke generation</p> <p>Appendix 2 – Test procedure for gas measuring</p> <p>The Resolution details a classification system based on the maximum specific optical density of smoke occurring during the test, averaged over three replicate tests, carried out in each of the three test conditions.</p> <p>In addition, the Resolution specifies limits for seven toxic gases which must not be exceeded in any of the three test conditions.</p>
Fire test study group/EGOLF	<p>Certain aspects of some fire test specifications are open to different interpretations. The Fire Test Study Group and EGOLF have identified a number of such areas and has agreed Resolutions which define common agreement of interpretations between fire test laboratories which are members of the Groups. Where such Resolutions are applicable to this test they have been followed.</p>
Instruction to test	<p>The test was conducted on the 21st & 22nd April and 19th May 2021 at the request of WSBL Ltd., the sponsor of the test.</p>
Conditioning of specimens	<p>The specimens were received on the 16th March 2021.</p> <p>Prior to test the specimens were conditioned to constant mass at a temperature of $23 \pm 2^{\circ}\text{C}$ and a relative humidity of $50 \pm 5\%$.</p>
Test apparatus data	<ul style="list-style-type: none">• Inner volume of the gas cell = 0.2 Litres• Inner volume of gas sampling line = 0.1 Litres• Length of gas sampling line = 2 metres• Max capacity of gas sampling pump = 4.5L/min
Exposed face	<p>The foil face of the specimens was exposed to the radiant heat of the test when the specimens were mounted in the test position.</p>
Substrate	<p>The specimens were tested with a 12mm thick calcium silicate substrate present.</p>
Provision of test specimens	<p>The specimens were supplied by the sponsor of the test. Warringtonfire was not involved in any selection or sampling procedure. The results stated in this report apply to the sample as received.</p>

Document No.: 502169
Author: K. Deluce
Client: WSBL Ltd.

Page No.: 4 of 13
Issue Date: 8th July 2021
Issue No.: 1



0249

Description of Test Specimens

The description of the system given below has been prepared from information provided by the sponsor of the test. This information has not been independently verified by [Warringtonfire](#). All values quoted are nominal, unless tolerances are given.

General description		Polymeric decoupled acoustic barrier mat	
Product reference of overall composite		“Revac [®] Momentum [™] S FF”	
Name of manufacturer of overall composite		WSBL Ltd	
Thickness of overall composite		5.0mm (stated by sponsor) 5.52mm (determined by Warringtonfire)	
Density of overall composite		2.0g/cm ³ (stated by sponsor) 1.88g/cm ³ (determined by Warringtonfire)	
Facing	Foil	Generic type	Aluminium foil
		Product reference	See Note 1 below
		Name of manufacturer	Rothel
		Thickness	See Note 1 below
		Weight per unit area	See Note 1 below
		Colour	Silver
		Flame retardant details	See Note 2 below
	Reinforcing scrim	Generic type	Glass fibre scrim
		Product reference	See Note 1 below
		Name of manufacturer	Rothel
		Colour	White
		Thickness	See Note 1 below
		Weight per unit area	See Note 1 below
		Type of weave / cell dimensions	Plain weave 5mm x 5mm
	Flame retardant details	See Note 2 below	
	Adhesive	Generic type	Polythene hot melt
		Product reference	See Note 1 below
		Name of manufacturer	Rothel
		Colour	Clear
		Application rate	25g/m ²
		Application method	See Note 1 below
Flame retardant details		See Note 2 below	
Curing process	See Note 1 below		

Continued on next page

Rubber	Generic type	Thermoplastic elastomer
	Product reference	“Revac [®] Momentum [™] S”
	Detailed description	See Note 3 below
	Name of manufacturer	WSBL Ltd
	Thickness	5.0mm
	Density	2.0g/cm ³
	Weight per unit area	10kg/m ²
	Colour reference	Black
	Flame retardant details	See Note 2 below
Brief description of manufacturing process		See Note 3 below

Note 1. The sponsor of the test was unable to provide this information.

Note 2. The sponsor of the test has confirmed that no flame retardant additives were utilised in the production of the component.

Note 3. The sponsor of the test was unwilling to provide this information.

The description of the specimens as given above is not as detailed as would usually be the case for descriptions included in [Warringtonfire](#) test reports and the description may not fully comply with the requirements of the test standard. In all other respects however the tests were conducted fully in accordance with the requirements of the test standard and the test results are valid.

Test Results

Test procedure

A 75mm x 75mm specimen is mounted horizontally inside a smoke chamber of the design specified in ISO 5659 Part 2, 25mm below a cone shaped, radiant electric heater capable of producing a uniform irradiance of 50kW/m² on the specimen surface. A premixed propane/air pilot flame of length 30mm may be applied 10mm above the specimen surface.

Three replicate specimens are tested in each of the following three test conditions at a mounted specimen distance of either 25mm or 50mm below the cone radiant heater:

1. Irradiance of 25kW/m² in the presence of pilot flame.
2. Irradiance of 25kW/m² in the absence of pilot flame.
3. Irradiance of 50kW/m² in the absence of pilot flame.

The attenuation of a light beam passing through the evolved smoke is measured and the results are reported in terms of the maximum Specific Optical Density attained during the test, given by the equation:

$$D_s = (V/(A*L)) * \log_{10} (100/T)$$

Where:

V	=	total volume of the chamber (m ³)
A	=	exposed area of the specimen (m ²)
L	=	optical length (m) of smoke measurement
T	=	% light transmitted.

The initial test at each test condition is twenty minutes to verify the possible existence of a second minimum transmittance value. If the minimum transmittance value is shown by the initial test to occur within the first ten minutes, then subsequent tests for that test condition may have an exposure of 10 minutes. Otherwise, the tests shall last twenty minutes.

In the case of intumescent materials, a preliminary test at each test condition is performed with the specimen mounted horizontally inside the chamber 25mm below the cone shaped, radiant electric heater. In accordance with ISO 5659-2, if the specimen should intumesce more than 10mm during these preliminary tests, the mount distance of the specimen is to increase from 25mm to 50mm below the radiant heater.

The sampling of the fire effluent created in the chamber during the test for the analysis of the concentration of the seven different gases for which criteria are given is conducted using Fourier Transform Infra Red (FT-IR) analysis. The FT-IR has been calibrated by the analyser manufacturer (Thermo) using library spectrum and bottled gases.

In all cases, the sample is taken from the geometric centre of the chamber and sample lines are kept as short as possible to minimise sample losses.

The gas measurement in each case is carried out when the maximum smoke density is obtained called Dm Sampling Time (DmST). This time is determined by the initial smoke density measurement test performed at each test condition.

Sampling Response Period (SRP) is the minimum time necessary during the sampling period to completely load the FT-IR gas cell including the time to transfer the effluents flow from the smoke chamber into the cell. Sampling commences at DmST – (SRP x 0.5) seconds.

Test Results

The test results relating to smoke production are detailed in Appendix I of this report.

The test results relating to toxicity production are detailed in Appendix II of this report.

Observations recorded during the tests are detailed in Appendix III of this report.

Summary of Results

The specimens meet all the criteria for smoke generation and toxicity for bulkhead, wall and ceiling products as specified in the Resolution.

Validity

This report is valid for a period of fifteen years from the date of test.

This report may only be reproduced in full. Extracts or abridgements shall not be published without permission of [Warringtonfire](#).

The tests results relate only to the specimens of the product in the form in which they are tested, they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use. Small differences in the composition or thickness of the product may significantly affect the performance during the test and may therefore invalidate the test results. Care should be taken to ensure that any product which is supplied or used is fully represented by the specimens that were tested.

The quantity of each specific toxic gas species generated is dependant upon the fire model used and the burning behaviour of the specimen during each individual fire test. The quantitative determination of combustion products therefore relates only to the specimens tested under the conditions stated and when combustion occurs as described in this test report.

References

1. IMO Resolution MSC 307(88): Annex 1, Part 2: Smoke And Toxicity Test.
2. ISO 5659-2: 2017 Plastics - Smoke Generation - Part 2: Determination of Optical Density by a Single Chamber Test.

Appendix I – Smoke production during test

Condition		25kW/m ² In The Presence Of A Pilot Flame	25kW/m ² In The Absence Of A Pilot Flame	50kW/m ² In The Absence Of A Pilot Flame	
Maximum Specific Optical Density	Specimen 1	Ds (max)	1	1	
		Time to Ds (max)	1200	1200	
		D (Clear beam)	0	1	
	Specimen 2	Ds (max)	0	1	2
		Time to Ds (max)	67	1035	1193
		DmST**	1200	1200	1200
		D (Clear beam)	0	0	0
	Specimen 3	Ds (max)	0	1	2
		Time to Ds (max)	57	1091	1199
		DmST**	1200	1200	1200
		D (Clear beam)	0	0	1
	Sampling Response Time (SRP) (Secs)		10	10	10
Averaged Ds (max)		0	1	2	
Limit		*	*	*	

Where * indicates the SOD must be ≤500 for floor coverings, ≤400 primary deck coverings, ≤400 plastic pipes and ≤200 for bulkhead, wall and ceiling linings.

** indicates time the maximum smoke density determined by the initial smoke density measurement test performed in each test condition. The gas measurement in each case is conducted at this pre-determined time.

Appendix II – Toxicity production during test

TOXICITY DATA

Irradiance level of 25kW/m² in the presence of a pilot flame.

GAS		Maximum Gas Concentration C (ppm)		Average (ppm)	Limit (ppm)
		1	2		
Carbon Monoxide	CO	7	3	5	1450
Hydrochloric Acid	HCl	ND	ND	ND	N/A
	Correction Factor (<i>Cca</i>)	ND	ND	ND	
	Corrected max. conc.	ND	ND	ND	600
Hydrogen Bromide	HBr	ND	ND	ND	600
Hydrogen Fluoride	HF	ND	ND	ND	600
Hydrogen Cyanide	HCN	ND	ND	ND	140
Nitrous Fumes	NO _x	11	10	11	350
Sulphur Dioxide	SO ₂	ND	ND	ND	*

TOXICITY DATA

Irradiance level of 25kW/m² in the absence of a pilot flame.

GAS		Maximum Gas Concentration C (ppm)		Average (ppm)	Limit (ppm)
		1	2		
Carbon Monoxide	CO	ND	ND	ND	1450
Hydrochloric Acid	HCl	ND	ND	ND	N/A
	Correction Factor (<i>Cca</i>)	2	1	2	
	Corrected max. conc.	2	1	2	600
Hydrogen Bromide	HBr	ND	ND	ND	600
Hydrogen Fluoride	HF	ND	ND	ND	600
Hydrogen Cyanide	HCN	ND	ND	ND	140
Nitrous Fumes	NO _x	1	1	1	350
Sulphur Dioxide	SO ₂	ND	ND	ND	*

TOXICITY DATAIrradiance level of 50kW/m² in the absence of a pilot flame.

GAS		Maximum Gas Concentration C (ppm)		Average (ppm)	Limit (ppm)
		1	2		
Carbon Monoxide	CO	4	3	4	1450
Hydrochloric Acid	HCl	ND	ND	ND	N/A
	Correction Factor (Cca)	1	1	1	
	Corrected max. conc.	1	1	1	600
Hydrogen Bromide	HBr	ND	ND	ND	600
Hydrogen Fluoride	HF	ND	ND	ND	600
Hydrogen Cyanide	HCN	ND	ND	ND	140
Nitrous Fumes	NO _x	1	1	1	350
Sulphur Dioxide	SO ₂	ND	ND	ND	*

Key:

ND indicates non-detected.

* indicates the SO₂ must be ≤200 for floor coverings and the SO₂ must be ≤120 for other applications.

NB. Correction factor is the concentration of HCl gas retained on the filter throughout the complete test duration.

Appendix III – Observations during test

Specimen No.	25kW/m ² In The Presence Of A Pilot Flame			25kW/m ² In The Absence Of A Pilot Flame			50kW/m ² In The Absence Of A Pilot Flame		
	1	2	3	4	5	6	7	8	9
Colour of smoke produced	Dark	Dark	Dark	Dark	Dark	Dark	Dark	Dark	Dark
Expansion distance towards heater (mm)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Ignition time in seconds	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Extinction time in seconds	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mass Loss (g)	0.00	0.90	0.50	0.40	0.60	0.40	0.80	0.60	0.60
Time to Ds (max)	1200	67	57	1200	1035	1091	1200	1193	1199
Ds (max)	1	0	0	1	1	1	1	2	2
D (Clear beam)	0	0	0	1	0	0	0	0	1
Test duration in seconds	1200	1200	1200	1200	1200	1200	1200	1200	1200
* = Did not re-ignite N/A = Not Applicable									

Revision History

Issue No :	Issue Date :
Revised By:	Approved By:
Reason for Revision:	

Issue No :	Issue Date :
Revised By:	Approved By:
Reason for Revision:	